



NOTE 1: Locate the gas meter on a wall beneath a forward-sloping or hipped roof, where the roofing material is either composite or metal, the overhang is at least 28 inches, and the wall height is less than 25 feet.

NOTE 2: IGC must grant approval for alternate locations. A gas meter shelter may be required in some cases.